



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-5126CP0616**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
<b>Distributor</b> <i>Vertreiber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)
<b>Product Description</b> <i>Produktbezeichnung</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
<b>Model</b> <i>Modell</i>	REFALIT®
<b>Test Reports</b> <i>Prüfberichte</i>	supplement test: 18/212/5126/2 from 18.09.2018 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)

**Date of Expiry / File No.** 08.05.2022 / 18-0746-GNA  
**Ablaufdatum / Aktenzeichen**

02.10.2018 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
REFALIT®	max. operating pressure: 1/5 bar	depending on the application

**certified Components****zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5123CP0615	Flat sealing materials on synthetic fiber basis	REFALIT®/REFALIT®	WILLBRANDT KG

**Hints of Utilization / Remarks****Verwendungshinweise / Bemerkungen**

field of application for maximum operation pressure of 1 bar: screw connections of gas meters according to DIN 3376-1 and DIN 3376-2 as well as flange connections of gas meters according to DIN 3376-2

field of application for maximum operation pressure of 5 bar: screw connections according to DIN EN 10241 and DIN EN 10242 also flange connections according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2 of pressure regulators and turning piston gas meters